

Rogue CC

Building Type Community_College	County Josephine	
Street 3345 Redwood Hwy		
City Grants Pass	State OR	Zip 97527
Latitude 42.41098	Longitude 123.39253	
Tracking Code Miller 2004-05	Inspection Date 7/26/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Tertiary		0	0	0	0	0	0	0	0	0


Redwood - Library & Wiseman Tutoring Ctr.

Final RVS Score

Final Type	Final Score
C2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1978	1978	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
20147	1	No	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		None	
Falling Hazards		Poor Conditions	
None			
None			
None			