

Rural/Metro Fire Dept

Rural/Metro Fire Dept

Jose_fir06A

Building Type Fire - RFPD	County Josephine	
Street 2375 Foothill Blvd.		
City Grants Pass	State OR	Zip 97526
Latitude 42.43644	Longitude 123.28953	
Tracking Code New Building	Inspection Date 7/26/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	0	0	0	-0.4	0	0	1.4
Secondary	W2	3.8	-2	0	0	2.4	-0.4	0	0	3.8
Tertiary		0	0	0	0	0	0	0	0	0

Rural/Metro Fire Dept

Final RVS Score

Final Type	Final Score
RM1	1.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1997	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13800	1	No	No
Plan Irregularities		Vertical Irregularities	
None		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SW Secondary Structural Type			

