

# Williams RFPD

Williams RFPD

Jose\_fir09A

Building Type Fire - RFPD	County Josephine	
Street 215 E Fork Rd.		
City Williams	State OR	Zip 97544
Latitude 42.21781	Longitude 123.27358	
Tracking Code RVS in 2006	Inspection Date 7/28/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	-0.5	0	0	0	0	0	3.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Williams RFPD

## Final RVS Score

Final Type	Final Score
W1	3.9

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
Reentrant Corners: L Shaped		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Plan Irregularity Secondary			

