

Evergreen Elementary School

Three Rivers/Josephine County SD

Jose_sch07A

Building Type	County	
School	Josephine	
Street		
520 W River St.		
City	State	Zip
Cave Junction	OR	97523
Latitude	Longitude	
42.16991	123.6525	
Tracking Code	Inspection Date	
RVS in 2006	7/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Evergreen Elementary School

Final RVS Score

Final Type	Final Score
RM1	2.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Evergreen Elementary School

Jose_sch07A

Enrollment 469	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1967	Est. Decade Built 1960
Total Area (square ft) 59342	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 SE Primary Structural Type			

Evergreen Elementary School

Three Rivers/Josephine County SD

Jose_sch07B

Building Type	County	
School	Josephine	
Street		
520 W River St.		
City	State	Zip
Cave Junction	OR	97523
Latitude	Longitude	
42.16973	123.65211	
Tracking Code	Inspection Date	
RVS in 2006	7/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	0	-0.8	0	3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Evergreen Elementary School

Final RVS Score

Final Type	Final Score
W2	3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Evergreen Elementary School

Jose_sch07B

Enrollment 469	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1967	Est. Decade Built 1960
Total Area (square ft) 59342	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

Evergreen Elementary School

Three Rivers/Josephine County SD

Jose_sch07C

Building Type	County	
School	Josephine	
Street		
520 W River St.		
City	State	Zip
Cave Junction	OR	97523
Latitude	Longitude	
42.16989	123.65296	
Tracking Code	Inspection Date	
RVS in 2006	7/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Evergreen Elementary School

Final RVS Score

Final Type	Final Score
RM1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Evergreen Elementary School

Jose_sch07C

Enrollment 469	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1967	Est. Decade Built 1960
Total Area (square ft) 59342	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 E General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Evergreen Elementary School

Three Rivers/Josephine County SD

Jose_sch07D

Building Type	County	
School	Josephine	
Street		
520 W River St.		
City	State	Zip
Cave Junction	OR	97523
Latitude	Longitude	
42.17037	123.65249	
Tracking Code	Inspection Date	
RVS in 2006	7/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Evergreen Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Evergreen Elementary School

Jose_sch07D

Enrollment 469	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1960	Est. Decade Built 1960
Total Area (square ft) 59342	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 S General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Evergreen Elementary School

Three Rivers/Josephine County SD

Jose_sch07E

Building Type	County	
School	Josephine	
Street		
520 W River St.		
City	State	Zip
Cave Junction	OR	97523
Latitude	Longitude	
42.17005	123.65225	
Tracking Code	Inspection Date	
RVS in 2006	7/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Evergreen Elementary School

Final RVS Score

Final Type	Final Score
RM1	2.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Evergreen Elementary School

Jose_sch07E

Enrollment 469	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1967	Est. Decade Built 1960
Total Area (square ft) 59342	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	