

Hidden Valley High School

Three Rivers/Josephine County SD

Jose_sch15A

Building Type	County	
School	Josephine	
Street		
651 Murphy Creek Rd.		
City	State	Zip
Grants Pass	OR	97527
Latitude	Longitude	
42.32584	123.33675	
Tracking Code	Inspection Date	
RVS in 2006	7/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hidden Valley High School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Hidden Valley High School

Jose_sch15A

Enrollment 858	Year Built (Field Verified) 1976	Year Built (Alt. Source) 1976	Est. Decade Built 1970
Total Area (square ft) 145600	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
W Plan Irregularity Primary	W Vertical Irregularity Primary	W Field Verified Year Built	
N Plan Irregularity Secondary	N General Site		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries