

Allen Dale Elementary School

Grants Pass SD 7

Jose_sch20A

Building Type	County		
School	Josephine		
Street			
2320 Williams Hwy			
City	State	Zip	
Grants Pass	OR	97527	
Latitude	Longitude		
42.41058	123.34845		
Tracking Code	Inspection Date		
RVS in 2006	7/19/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Allen Dale Elementary School

Final RVS Score

Final Type	Final Score
C2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Allen Dale Elementary School

Jose_sch20A

Enrollment 487	Year Built (Field Verified) 1961	Year Built (Alt. Source) 1961	Est. Decade Built 1960
Total Area (square ft) 48829	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE General Site	N Vertical Irregularity Primary	W Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Allen Dale Elementary School

Grants Pass SD 7

Jose_sch20B

Building Type	County	
School	Josephine	
Street		
2320 Williams Hwy		
City	State	Zip
Grants Pass	OR	97527
Latitude	Longitude	
42.41043	123.34889	
Tracking Code	Inspection Date	
RVS in 2006	7/19/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	-0.5	0	2.4	0	0	0	4.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Allen Dale Elementary School

Final RVS Score

Final Type	Final Score
C2	4.7

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Allen Dale Elementary School

Jose_sch20B

Enrollment 487	Year Built (Field Verified) 1961	Year Built (Alt. Source) 1961	Est. Decade Built 1990
Total Area (square ft) 48524	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries