

Klamath County Fire District 1

Klam_fir01A

Klamath Co Fire Dist #1

Building Type Fire - RFPD	County Klamath	
Street 4801 Highway 97 N		
City Klamath Falls	State OR	Zip 97601
Latitude 42.26915	Longitude 121.80986	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Klamath County Fire District 1

Final RVS Score

Final Type	Final Score
RM1	2.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Klamath County Fire District 1

Klam_fir01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	