

# Klamath County Fire District 1

Klamath Co Fire Dist #1

Klam\_fir02A

Building Type	County	
Fire - RFPD	Klamath	
Street		
143 N. Broad St.		
City	State	Zip
Klamath Falls	OR	97601
Latitude	Longitude	
42.22911	121.77541	
Tracking Code	Inspection Date	
RVS in 2006	7/21/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	0	-0.5	-0.2	0	0	-0.6	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Klamath County Fire District 1

## Final RVS Score

Final Type	Final Score
URM	0.5

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Klamath County Fire District 1

Klam\_fir02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1931	1931	1930
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
6098	2	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	



NW General Site



W Other



S Seismic Upgrade  
while not a true seismic upgrade this does serve to stiffen torsional probs w/reinforce brick.



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries