

Klamath County Fire District 1

Klamath Co Fire Dist #1

Klam_fir08A

Building Type Fire - RFPD	County Klamath	
Street 7110 Hillyard Ave		
City Klamath Falls	State OR	Zip 97603
Latitude 42.19992	Longitude 121.70243	
Tracking Code RVS in 2006	Inspection Date 7/21/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	-0.4	0	0	2.8
Secondary	S2	3	0	0	0	0	-0.4	0	0	2.6
Tertiary	RM1	2.8	0	0	0	0	-0.4	0	0	2.4

Klamath County Fire District 1

Final RVS Score

Final Type	Final Score
RM1	2.4

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Klamath County Fire District 1

Klam_fir08A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1978	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
83967	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW General Site		S Secondary Structural Type	
		S Primary Structural Type SAYS BUTLER	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries