

# Klamath County Fire District 1

Klam\_fir09A

Klamath Co Fire Dist #1

Building Type Fire - RFPD	County Klamath	
Street 1661 Mitchell St.		
City Klamath Falls	State OR	Zip 97601
Latitude 42.21413	Longitude 121.75952	
Tracking Code RVS in 2006	Inspection Date 7/21/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Klamath County Fire District 1

## Final RVS Score

Final Type	Final Score
RM1	0.7

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Klamath County Fire District 1

Klam\_fir09A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1963	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
38460	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E	Vertical Irregularity Primary	SE	General Site
			
S	Plan Irregularity Primary		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries