

Crescent RFPD

Klam_fir15A

Crescent RFPD

Building Type Fire - RFPD	County Klamath	
Street 136727 Main St.		
City Crescent	State OR	Zip 97733
Latitude 43.46247	Longitude 121.69402	
Tracking Code RVS in 2006	Inspection Date 7/3/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	0	0	-0.6	0	4.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Crescent RFPD

Final RVS Score

Final Type	Final Score
W1	4.1

FEMA-154 Collapse Potential

Low (<1%)



Oregon Geology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE Other age_structure indicator		E Other building change	
			
		E Primary Structural Type	



Crescent RFPD

Klam_fir15B

Crescent RFPD

Building Type Fire - RFPD	County Klamath	
Street 136727 Main St.		
City Crescent	State OR	Zip 97733
Latitude 43.4624	Longitude 121.69391	
Tracking Code RVS in 2006	Inspection Date 7/3/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	1.6	0	-0.6	0	5.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Crescent RFPD

Final RVS Score

Final Type	Final Score
W1	5.7

FEMA-154 Collapse Potential


Low (<1%)



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		Other	
None		None	
None		None	



NE Poor Condition

