

Keno RFPD

Keno RFPD

Klam_fir17A

Building Type Fire - RFPD	County Klamath	
Street 14800 Puckett Rd		
City Keno	State OR	Zip 97627
Latitude 42.13375	Longitude 121.92389	
Tracking Code RVS in 2006	Inspection Date 7/19/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary	W1	4.4	0	-0.5	0	2.4	0	0	0	6.3
Tertiary		0	0	0	0	0	0	0	0	0

Keno RFPD

Final RVS Score

Final Type	Final Score
RM1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1975	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N	Plan Irregularity Primary	SE	Secondary Structural Type

