

Altamont Elementary School

Klamath County SD

Klam_sch03A

Building Type	County	
School	Klamath	
Street		
2450 Summers Ln		
City	State	Zip
Klamath Falls	OR	97603
Latitude	Longitude	
42.20511	121.73972	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	-0.8	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Altamont Elementary School

Final RVS Score

Final Type

Final Score

W2

-0.5

FEMA-154 Collapse Potential

Very High (100%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
275		1937	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
39032	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions