

# Henley Elementary School

Klamath County SD

Klam\_sch08A

Building Type School	County Klamath	
Street 8205 Hwy 39		
City Klamath Falls	State OR	Zip 97603
Latitude 42.15162	Longitude 121.69752	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	-0.8	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Henley Elementary School

### Final RVS Score

Final Type	Final Score
W2	-0.5

### FEMA-154 Collapse Potential

Very High (100%)

No  
Planview  
Available



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Henley Elementary School

Klam\_sch08A

Enrollment 367	Year Built (Field Verified) 1929	Year Built (Alt. Source) 1929	Est. Decade Built
Total Area (square ft) 28900	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	