

Peterson Elementary School

Klamath County SD

Klam_sch09A

Building Type	County	
School	Klamath	
Street		
4856 Clinton Ave		
City	State	Zip
Klamath Falls	OR	97603
Latitude	Longitude	
42.18988	121.72892	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Peterson Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Peterson Elementary School

Klam_sch09A

Enrollment 520	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1940
Total Area (square ft) 45600	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: U shaped Out of Plane Lateral-Force-Resistance Elements		Vertical Irregularities Steps in Elevation View: Single Change	
Falling Hazards None		Poor Conditions None	
 S General Site			