

Shasta Elementary School

Klamath County SD

Klam_sch10A

Building Type	County	
School	Klamath	
Street		
1951 Madison St		
City	State	Zip
Klamath Falls	OR	97603
Latitude	Longitude	
42.21158	121.71671	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Shasta Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Shasta Elementary School

Klam_sch10A

Enrollment 540	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built
Total Area (square ft) 62196	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	