

Stearns Elementary School

Klamath County SD

Klam_sch11A

Building Type School	County Klamath	
Street 3641 Crest St		
City Klamath Falls	State OR	Zip 97603
Latitude 42.19316	Longitude 121.74188	
Tracking Code Structural Engineering Report	Inspection Date 9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Stearns Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Stearns Elementary School

Klam_sch11A

Enrollment 257	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1958	Est. Decade Built
Total Area (square ft) 33780	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	