

Building Type	County
School	Klamath
Street	
300 Elm St	
City	State Zip
Chiloquin	OR 97624
Latitude	Longitude
42.56753	121.86341
Tracking Code	Inspection Date
Structural Engineering Report	9/15/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	-0.4	0	0	-1.2	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Chiloquin High School

## Final RVS Score

Final Type	Final Score
RM1	-0.5

## FEMA-154 Collapse Potential

Very High (100%)

No  
Planview  
Available



Oregon Geology

# Chiloquin High School

Klam\_sch14A

Enrollment 282	Year Built (Field Verified) 1937	Year Built (Alt. Source) 1937	Est. Decade Built
Total Area (square ft) 73680	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
Falling Hazards		Poor Conditions	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	
<input type="text"/>		<input type="text"/>	