


Mills Elementary School

Klamath Falls City Schools

Klam_sch20A

Building Type School	County Klamath	
Street 520 E Main St		
City Klamath Falls	State OR	Zip 97601
Latitude 42.22417	Longitude 121.76554	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	0	-0.6	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mills Elementary School

Final RVS Score

Final Type	Final Score
URM	-0.5

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mills Elementary School

Klam_sch20A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
485	1919	1919	1910
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
59914	1	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: U shaped		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
Parapets: Unreinforced Around Entire Building		None	
Unreinforced Chimneys		None	
None		None	
		S Field Verified Year Built non structural upgrade	SW Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mills Elementary School

Klamath Falls City Schools

Klam_sch20B

Building Type School	County Klamath	
Street 520 E Main St		
City Klamath Falls	State OR	Zip 97601
Latitude 42.22446	Longitude 121.76616	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	0	0	0	-0.6	0	-0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mills Elementary School

Final RVS Score

Final Type	Final Score
URM	-0.3

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mills Elementary School

Klam_sch20B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
485	1949	1919	1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
59914	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:Other (Adjacent Build/Entity)		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
None		Steps in Elevation View: Single Change	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S Field Verified Year Built		SW Elevation View	
		NW Plan Irregularity Secondary	

Mills Elementary School

Klamath Falls City Schools

Klam_sch20C

Building Type	County
School	Klamath
Street	
520 E Main St	
City	State Zip
Klamath Falls	OR 97601
Latitude	Longitude
42.22405	121.76615
Tracking Code	Inspection Date
RVS in 2006	7/20/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mills Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mills Elementary School

Klam_sch20C

Enrollment 485	Year Built (Field Verified) 1919	Year Built (Alt. Source) 1970	Est. Decade Built 1970
Total Area (square ft) 59914	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) Reentrant Corners: L Shaped None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
			
NE Plan Irregularity Secondary		E Field Verified Year Built	