

Building Type	County	
School	Klamath	
Street		
11110 Keno-Worden Rd		
City	State	Zip
Keno	OR	97627
Latitude		Longitude
42.12403		121.93149
Tracking Code		Inspection Date
Structural Engineering Report		9/15/2006

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Keno Elementary School

Final RVS Score

Final Type

Final Score

RM1

1.3

FEMA-154 Collapse Potential

Moderate (>1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
170		1976	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
40600	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions

