

Building Type	County	
School	Klamath	
Street		
2153 3rd St		
City	State	Zip
Malin	OR	97632
Latitude	Longitude	
42.01105	121.41167	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0



Malin Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (&gt;10%)

No  
Planview  
Available



Oregon Geology

# Malin Elementary School

Klam\_sch28A

Enrollment 141	Year Built (Field Verified) 1971	Year Built (Alt. Source) 1971	Est. Decade Built
Total Area (square ft) 31608	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	
			
S	General Site	S	General Site
			
S	General Site	S	General Site
			
S	General Site		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries