

Performing Arts

Lane_coc02A

Lane CC

Building Type		County	
Community_College		Lane	
Street			
4000 E 30th Ave			
City	State	Zip	
Eugene	OR	97405	
Latitude		Longitude	
44.01055		123.03262	
Tracking Code		Inspection Date	
Miller 2004-05		8/17/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary	S3	3.2	0	-0.5	0	0	0	0	0	2.7
Tertiary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3

Performing Arts

Final RVS Score

Final Type


Final Score

C2

1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1975	1975	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
48156	2	Yes	No

Plan Irregularities	Vertical Irregularities
Yes: Unknown	Yes: Unknown

Falling Hazards	Poor Conditions
None	
None	
None	