

Air Technology

Lane_coc06A

Lane CC

Building Type	County	
Community_College	Lane	
Street		
4000 E 30th Ave		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.00999	123.03098	
Tracking Code	Inspection Date	
Miller 2004-05	8/17/2005	

Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card


Air Technology

Final RVS Score

Final Type	Final Score
PC2	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1968	1968	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
35014	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
Falling Hazards		Poor Conditions	
None			
None			
None			

