

# Industrial Technology - Bldg "D"

Lane\_coc13A

Lane CC

Building Type Community_College	County Lane	
Street 4000 E 30th Ave		
City Eugene	State OR	Zip 97405
Latitude 44.00863	Longitude 123.03327	
Tracking Code Miller 2004-05	Inspection Date 8/17/2005	

Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC2	2.4	-1	-0.5	0	0	0	0	0	0.9
Secondary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3
Tertiary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3


Industrial Technology - Bldg "D"

## Final RVS Score

Final Type	Final Score
PC2	0.9

## FEMA-154 Collapse Potential

High (>10%)



# Industrial Technology - Bldg "D"

Lane\_coc13A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1968	1968	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
20921	2	Yes	No
Plan Irregularities		Vertical Irregularities	
None		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			