

# Workforce Training Center/Apprenticeship

Lane\_coc16A

Lane CC

|                   |       |                 |  |
|-------------------|-------|-----------------|--|
| Building Type     |       | County          |  |
| Community_College |       | Lane            |  |
| Street            |       |                 |  |
| 4000 E 30th Ave   |       |                 |  |
| City              | State | Zip             |  |
| Eugene            | OR    | 97405           |  |
| Latitude          |       | Longitude       |  |
| 44.00837          |       | 123.03386       |  |
| Tracking Code     |       | Inspection Date |  |
| Miller 2004-05    |       | 8/17/2005       |  |

Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

|           | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary   | PC2  | 2.4         | -1         | -0.5       | 0        | 0          | 0      | 0      | 0      | 0.9       |
| Secondary | S1   | 2.8         | -1         | -0.5       | 0        | 0          | 0      | 0      | 0      | 1.3       |
| Tertiary  | S2   | 3           | -1.5       | -0.5       | 0        | 0          | 0      | 0      | 0      | 1         |

Workforce Training Center/Apprenticeship

## Final RVS Score

Final Type


Final Score

PC2

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

|                        |                             |                          |                    |
|------------------------|-----------------------------|--------------------------|--------------------|
| Enrollment             | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built  |
|                        | 1968                        | 1968                     | 1960               |
| Total Area (square ft) | Number of Stories           | Basement                 | Pounding Potential |
| 87888                  | 2                           | Yes                      | No                 |

|                     |                         |
|---------------------|-------------------------|
| Plan Irregularities | Vertical Irregularities |
| Yes: Unknown        | Yes: Unknown            |
|                     |                         |
|                     |                         |

|                       |                 |
|-----------------------|-----------------|
| Falling Hazards       | Poor Conditions |
| Other: Light Cladding |                 |
| None                  |                 |
| None                  |                 |

