

# Branch - Downtown Center

Lane\_coc19A

Lane CC

Building Type Community_College	County Lane	
Street 4000 E 30th Ave		
City Eugene	State OR	Zip 97405
Latitude 44.04808	Longitude 123.09231	
Tracking Code Miller 2004-05	Inspection Date 8/17/2005	

Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Tertiary		0	0	0	0	0	0	0	0	0


Branch - Downtown Center

## Final RVS Score

Final Type	Final Score
C2	1.3

## FEMA-154 Collapse Potential

Moderate (>1%)



# Branch - Downtown Center

Lane\_coc19A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1977	1977	1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
56508	3	Yes	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			