

# Springfield Fire Station 4

City of Springfield

Lane\_fir01A

Building Type	County	
Fire - City	Lane	
Street		
1475 5th St		
City	State	Zip
Springfield	OR	97477
Latitude	Longitude	
44.05903	123.01896	
Tracking Code	Inspection Date	
RVS in 2006	8/1/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Springfield Fire Station 4

## Final RVS Score

Final Type	Final Score
RM1	1.3

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Springfield Fire Station 4

Lane\_fir01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S	Primary Structural Type	W	Plan Irregularity Primary reentrant corner



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries