

Springfield Fire Station 2

City of Springfield

Lane_fir02A

Building Type Fire - City	County Lane	
Street 4765 Main St		
City Springfield	State OR	Zip 97477
Latitude 44.0454	Longitude 122.95059	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary	W2	4.8	-3	-0.5	0	0	0	0	0	1.3
Tertiary		0	0	0	0	0	0	0	0	0

Springfield Fire Station 2

Final RVS Score

Final Type	Final Score
RM1	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Springfield Fire Station 2

Lane_fir02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1962	1962	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S	Vertical Irregularity Primary	S	Vertical Irregularity Primary
			
N	Field Verified Year Built	1962	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries