

# Westfir City Hall w/Attached Fire Dept

City of Westfir

Lane\_fir06A

Building Type Fire - City	County Lane	
Street 47441 Westoak Road		
City Westfir	State OR	Zip 97492
Latitude 43.75838	Longitude 122.49124	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	0	-0.2	0	0	5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Westfir City Hall w/Attached Fire Dept

**Final RVS Score**

Final Type	Final Score
W1	5

**FEMA-154 Collapse Potential**

Low (<1%)
-----------



# Westfir City Hall w/Attached Fire Dept

Lane\_fir06A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W	General Site		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries