

Springfield Fire Station 1

City of Springfield

Lane_fir08A

Building Type Fire - City	County Lane	
Street 6853 Main St		
City Springfield	State OR	Zip 97477
Latitude 44.04526	Longitude 122.90512	
Tracking Code RVS in 2006	Inspection Date 8/1/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Springfield Fire Station 1

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Springfield Fire Station 1

Lane_fir08A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E Other no torsion trucks can drive through.		S Other under construction to remove mold.	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries