

Lane Rural Fire Rescue

Lane Rural Fire Rescue

Lane_fir18A

Building Type Fire - RFPD	County Lane									
Street 90825 Alvadore Rd										
City Alvadore	State OR	Zip 97409								
Latitude 44.12606	Longitude 123.26424									
Tracking Code RVS in 2006	Inspection Date 7/7/2006									
Seismicity Zone: High										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	0	-0.6	0	2.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lane Rural Fire Rescue

Final RVS Score

Final Type S3	Final Score 2.6
------------------	--------------------

FEMA-154 Collapse Potential

Low (<1%)







OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Lane Rural Fire Rescue

Lane_fir18A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries