

Lane Rural Fire Rescue

Lane Rural Fire Rescue

Lane_fir19A

Building Type Fire - RFPD	County Lane	
Street 29999 Hallet St		
City Eugene	State OR	Zip 97402
Latitude 44.11494	Longitude 123.16734	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	0	0	0	3.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lane Rural Fire Rescue

Final RVS Score

Final Type	Final Score
S3	3.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Lane Rural Fire Rescue

Lane_fir19A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Vertical Irregularity Primary		NE Vertical Irregularity Primary	
		SW General Site	