

Mckenzie Fire & Rescue

Lane_fir25A

Mckenzie Fire & Rescue

Building Type Fire - RFPD	County Lane	
Street 45627 Gate Creek Rd		
City Vida	State OR	Zip 97488
Latitude 44.14745	Longitude 122.57258	
Tracking Code New Building	Inspection Date 7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	1.6	-0.8	0	0	5.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mckenzie Fire & Rescue

Final RVS Score

Final Type	Final Score
W2	5.1

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mckenzie Fire & Rescue

Lane_fir25A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			2000
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S	General Site	W	Plan Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries