

# South Lane County F&R

Lane\_fir29A

South Lane County F&R

Building Type Fire - RFPD	County Lane	
Street 233 Harrison Ave		
City Cottage Grove	State OR	Zip 97424
Latitude 43.78968	Longitude 123.06606	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

South Lane County F&R

## Final RVS Score

Final Type	Final Score
C2	0.7

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# South Lane County F&R

Lane\_fir29A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE	Plan Irregularity Primary	E	General Site
			
		E	Other roof structure



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries