

Blue River VFD

Blue River RFPD

Lane_fir34A

Building Type Fire - RFPD	County Lane	
Street 51730 Echo St		
City Blue River	State OR	Zip 97413
Latitude 44.15397	Longitude 122.33949	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	1.6	-0.2	0	0	6.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Blue River VFD

Final RVS Score

Final Type	Final Score
W1	6.1

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	

