

Eugene Fire Station 12 Airport

City of Eugene

Lane_fir52A

Building Type	County	
Fire - City	Lane	
Street		
28827 Douglas Dr		
City	State	Zip
Eugene	OR	97402
Latitude	Longitude	
44.11797	123.21327	
Tracking Code	Inspection Date	
RVS in 2006	7/7/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	0	0	3.7
Secondary	C2	2.8	-1	-0.5	0	0	0	0	0	1.3
Tertiary		0	0	0	0	0	0	0	0	0

Eugene Fire Station 12 Airport

Final RVS Score

Final Type	Final Score
C2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Eugene Fire Station 12 Airport

Lane_fir52A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Non-Parallel System		Steps in Elevation View: Single Change	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E Vertical Irregularity Primary non-parallel system also		W General Site Airport fence in foreground.	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries