

Lane County Fire District 1 - Walton Station

Lane_fir59A

Lane Co Fire Dist #1

Building Type		County	
Fire - RFPD		Lane	
Street			
18796 Transformer Rd			
City	State	Zip	
Walton	OR	97490	
Latitude	Longitude		
44.03067	123.58865		
Tracking Code	Inspection Date		
RVS in 2006	8/4/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lane County Fire District 1 - Walton Station

Final RVS Score

Final Type


Final Score

S3

2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW General Site



SE General Site

