

Lane County Fire District 1

Lane Co Fire Dist #1

Lane_fir60A

Building Type	County	
Fire - RFPD	Lane	
Street		
84501 McBeth Rd		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
43.95546	123.13676	
Tracking Code	Inspection Date	
RVS in 2006	7/21/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	2.4	0	0	0	6.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lane County Fire District 1

Final RVS Score

Final Type	Final Score
W1	6.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Lane County Fire District 1

Lane_fir60A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		Internal Discontinuous Diaphragm (large internal opening)	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E	General Site	NE	Vertical Irregularity Primary opening in roof