

Mohawk Valley RFD

Lane_fir64A

Mohawk Valley RFD

Building Type		County	
Fire - RFPD		Lane	
Street			
37467 Parsons Creek Rd			
City	State	Zip	
Springfield	OR	97478	
Latitude		Longitude	
44.17915		122.88534	
Tracking Code		Inspection Date	
RVS in 2006		7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	1.6	-0.2	0	0	6.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mohawk Valley RFD

Final RVS Score

Final Type

Final Score

W1

6.1

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Plan Irregularity Primary

