

Mohawk Valley RFD

Lane_fir66A

Mohawk Valley RFD

Building Type Fire - RFPD	County Lane	
Street 90605 Nadeau Rd		
City Springfield	State OR	Zip 97478
Latitude 44.12736	Longitude 122.91945	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	1.6	0	-0.6	0	5.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mohawk Valley RFD

Final RVS Score

Final Type	Final Score
W1	5.7

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mohawk Valley RFD

Lane_fir66A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: T shaped		None	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W Plan Irregularity Secondary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries