

# Santa Clara RFPD

Santa Clara RFPD

Lane\_fir68A

Building Type Fire - RFPD	County Lane	
Street 2600 River Rd		
City Eugene	State OR	Zip 97404
Latitude 44.10188	Longitude 123.13113	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9

Santa Clara RFPD

## Final RVS Score

Final Type	Final Score
RM1	0.9

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E	Plan Irregularity Primary	NE	Vertical Irregularity Primary
			
		SE	General Site

