

Peace Harbor Hospital - Florence

Lane_hos02A

PeaceHealth System NFP

Building Type		County	
Hospital		Lane	
Street			
400 9th St			
City	State	Zip	
Florence	OR	97439	
Latitude		Longitude	
43.97318		124.1174	
Tracking Code		Inspection Date	
RVS in 2006		8/7/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Peace Harbor Hospital - Florence

Final RVS Score

Final Type

Final Score

RM1

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1989	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Non-Parallel System	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



N General Site
Also shows plan irregularity.



NE Plan Irregularity Primary



NW General Site



W Plan Irregularity Primary
non-parallel wall.