

Mckenzie-Willamette Medical Center

Triad Hospitals Inc For Profit

Lane_hos04A

Building Type	County	
Hospital	Lane	
Street		
1460 G St		
City	State	Zip
Springfield	OR	97477
Latitude	Longitude	
44.05295	123.00373	
Tracking Code	Inspection Date	
New Building	7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	0	-0.4	0	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mckenzie-Willamette Medical Center

Final RVS Score

Final Type	Final Score
W2	2.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mckenzie-Willamette Medical Center

Lane_hos04A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		2010	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
423000	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		None	
Reentrant Corners: L Shaped (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S	Plan Irregularity Primary	SW	Plan Irregularity Primary



OregonGeology


Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mckenzie-Willamette Medical Center

Triad Hospitals Inc For Profit

Lane_hos04B

Building Type	County	
Hospital	Lane	
Street		
1460 G St		
City	State	Zip
Springfield	OR	97477
Latitude	Longitude	
44.05338	123.0032	
Tracking Code	Inspection Date	
New Building	7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.2	-1	-0.5	0	2.4	-0.4	0	0	3.7
Secondary	S4	3.2	-1	-0.5	0	1.6	-0.4	0	0	2.9
Tertiary		0	0	0	0	0	0	0	0	0

Mckenzie-Willamette Medical Center

Final RVS Score

Final Type	Final Score
S4	2.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mckenzie-Willamette Medical Center

Lane_hos04B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		2010	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
423000	4	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: L Shaped (Adjacent Build/Entity)		None	
Non-Parallel System		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE Vertical Irregularity Primary		NE Plan Irregularity Primary and vertical irr.	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mckenzie-Willamette Medical Center

Triad Hospitals Inc For Profit

Lane_hos04C

Building Type Hospital	County Lane	
Street 1460 G St		
City Springfield	State OR	Zip 97477
Latitude 44.05356	Longitude 123.00371	
Tracking Code New Building	Inspection Date 7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	2.5	-1.5	-0.5	0	0	-0.4	0	0	0.1
Secondary	C2	2.8	-1	-0.5	0	2.4	-0.4	0	0	3.3
Tertiary		0	0	0	0	0	0	0	0	0


Mckenzie-Willamette Medical Center

Final RVS Score

Final Type	Final Score
C1	0.1

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mckenzie-Willamette Medical Center

Lane_hos04C

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		2010	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
423000	3	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Non-Parallel System		Steps in Elevation View: Very Irregular Changes	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W	Vertical Irregularity Secondary	NE	Vertical Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries