


Building Type		County	
Police - State		Lane	
Street			
3620 Gateway St			
City		State	Zip
Springfield		OR	97477
Latitude		Longitude	
44.08623		123.04335	
Tracking Code		Inspection Date	
RVS in 2006		7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	0	0	2.3
Secondary	W2	3.8	0	-0.5	0	0	0	0	0	3.3
Tertiary		0	0	0	0	0	0	0	0	0

OSP - Crime Lab

Final RVS Score

Final Type

Final Score

RM1

2.3

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NE General Site
bldg. on left



SE Plan Irregularity Primary