

# Junction City Police Dept

City of Junction City

Lane\_pol10A

Building Type	County
EOC-Public Safety Answering P	Lane
Street	
672 Greenwood St	
City	State Zip
Junction City	OR 97448
Latitude	Longitude
44.21982	123.2023
Tracking Code	Inspection Date
RVS in 2006	7/20/2006



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Tertiary		0	0	0	0	0	0	0	0	0

Junction City Police Dept

## Final RVS Score

Final Type	Final Score
RM1	0.7

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Junction City Police Dept

Lane\_pol10A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:L shaped (Adjacent Build/Entity)		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Parapets: General		None	
None		None	
None		None	
			
W Other pounding potential		E Plan Irregularity Primary step in elevation also	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries