

Oakridge Police Dept

City of Oakridge

Lane_pol12A

Building Type		County	
Police - City		Lane	
Street			
76435 Ash St.			
City	State	Zip	
Oakridge	OR	97463	
Latitude		Longitude	
43.74739		122.45704	
Tracking Code		Inspection Date	
RVS in 2006		7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	0	-0.8	0	0	1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Oakridge Police Dept

Final RVS Score

Final Type

Final Score

W2

1

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1961	1961	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities
None	Building On Hill or Sloped Site
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



E Vertical Irregularity Primary
a sloped site.



NE Field Verified Year Built
1961

