

Pleasant Hill High School

Lane_sch01A

Pleasant Hill SD 1

Building Type	County	
School	Lane	
Street		
36386 Hwy 58		
City	State	Zip
Pleasant Hill	OR	97455
Latitude	Longitude	
43.9568	122.91636	
Tracking Code	Inspection Date	
RVS in 2006	7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Pleasant Hill High School

Final RVS Score

Final Type	Final Score
RM1	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Pleasant Hill High School

Lane_sch01A

Enrollment 387	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1960
Total Area (square ft) 80180	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W General Site			

Pleasant Hill High School

Pleasant Hill SD 1

Lane_sch01B

Building Type School	County Lane	
Street 36386 Hwy 58		
City Pleasant Hill	State OR	Zip 97455
Latitude 43.9572	Longitude 122.91578	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	0	0	-1.2	0	0.6
Secondary	RM1	3.6	-2	0	0	0	0	-1.2	0	0.4
Tertiary		0	0	0	0	0	0	0	0	0

Pleasant Hill High School

Final RVS Score

Final Type RM1	Final Score 0.4
-------------------	--------------------

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Pleasant Hill High School

Lane_sch01B

Enrollment 387	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1960
Total Area (square ft) 80180	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards Unreinforced Chimneys None None		Poor Conditions None None None	
			SE General Site W General Site NW Other connection between arch and ground



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Pleasant Hill High School

Pleasant Hill SD 1

Lane_sch01C

Building Type School	County Lane	
Street 36386 Hwy 58		
City Pleasant Hill	State OR	Zip 97455
Latitude 43.95682	Longitude 122.91506	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	1.6	0	-0.6	0	6.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Pleasant Hill High School

Final RVS Score

Final Type	Final Score
W1	6.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Pleasant Hill High School

Lane_sch01C

Enrollment 387	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1980
Total Area (square ft) 80180	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

Pleasant Hill High School

Pleasant Hill SD 1

Lane_sch01D

Building Type	County
School	Lane
Street	
36386 Hwy 58	
City	State Zip
Pleasant Hill	OR 97455
Latitude	Longitude
43.95659	122.91546
Tracking Code	Inspection Date
RVS in 2006	7/20/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Secondary	W2	4.8	0	-0.5	0	0	0	-1.2	0	3.1
Tertiary		0	0	0	0	0	0	0	0	0

Pleasant Hill High School

Final RVS Score

Final Type	Final Score
RM1	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Pleasant Hill High School

Lane_sch01D

Enrollment 387	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1960
Total Area (square ft) 80180	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W Plan Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Pleasant Hill High School

Pleasant Hill SD 1

Lane_sch01E

Building Type School	County Lane	
Street 36386 Hwy 58		
City Pleasant Hill	State OR	Zip 97455
Latitude 43.95656	Longitude 122.91606	
Tracking Code RVS in 2006	Inspection Date 8/4/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Pleasant Hill High School

Final RVS Score

Final Type

RM1

Final Score

-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Pleasant Hill High School

Lane_sch01E

Enrollment 387	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1960
Total Area (square ft) 	Number of Stories 1	Basement No	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Building On Hill or Sloped Site None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Plan Irregularity Primary step in elevation	W Secondary Structural Type	W General Site	