


Adams Elementary School

Eugene SD 4J

Lane_sch02A

Building Type	County	
School	Lane	
Street		
950 W 22nd Ave		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.03496	123.10769	
Tracking Code	Inspection Date	
SER & RVS2006	8/4/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	0	0	3.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Adams Elementary School

Final RVS Score

Final Type	Final Score
W2	3.7

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Adams Elementary School

Lane_sch02A

Enrollment 183	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1980
Total Area (square ft) 47037	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	