

Awbrey Park Elementary School

Eugene SD 4J

Lane_sch03A

Building Type	County	
School	Lane	
Street		
158 Spring Creek Dr		
City	State	Zip
Eugene	OR	97404
Latitude	Longitude	
44.12367	123.13708	
Tracking Code	Inspection Date	
SER & RVS2006	7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Awbrey Park Elementary School

Final RVS Score

Final Type	Final Score
RM1	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Awbrey Park Elementary School

Lane_sch03A

Enrollment 472	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1967	Est. Decade Built 1960
Total Area (square ft) 56816	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
NE General Site			

Awbrey Park Elementary School

Eugene SD 4J

Lane_sch03B

Building Type	County	
School	Lane	
Street		
158 Spring Creek Dr		
City	State	Zip
Eugene	OR	97404
Latitude	Longitude	
44.1237	123.13796	
Tracking Code	Inspection Date	
SER & RVS2006	8/4/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Awbrey Park Elementary School

Final RVS Score

Final Type	Final Score
RM1	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Awbrey Park Elementary School

Lane_sch03B

Enrollment 472	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1967	Est. Decade Built 1960
Total Area (square ft) 56816	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Non-Parallel System None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries