

Crest Drive Elementary School

Eugene SD 4J

Lane_sch05A

Building Type	County	
School	Lane	
Street		
1155 Crest Dr		
City	State	Zip
Eugene	OR	97405
Latitude	Longitude	
44.01634	123.11051	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Crest Drive Elementary School

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Crest Drive Elementary School

Lane_sch05A

Enrollment 232	Year Built (Field Verified) 1963	Year Built (Alt. Source) 1963	Est. Decade Built
Total Area (square ft) 23562	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	